

LOCATION 716 & 714 Linwood Rd CITY Casstown  
BETWEEN EAST DR. STREET & Spencer STREET


	SIZE	TYPE	LENGTH	INSTALLED	-RETIRED-	-RENEWED-
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>61'</u>	<u>7-9-94</u>	<u>Tied over 115' SA</u>	
MAIN TO PROP. LINE					<u>EXT 3/4" CHN TO EXT</u>	
PROP. LINE TO BLDG.					<u>4" PLASTIC MAIN</u>	

ENTERS: 716 BRANCHED INTO: 714  
TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION \_\_\_\_\_

PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By EP  
MAIN-SIZE 4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1993  
DEPTH: 3 Ft. 6 In. LOCATION \_\_\_\_\_

"A" P/S READING P TOTAL ANODES 1\* 1 17\* \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u> <u>RISORS</u>	<u>1.2</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY