

LOCATION 1001 Linwood RdCITY GASTONIABETWEEN EAST DR.STREET & SPENCER AVE.

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	2"	P	24'	8-6-94	8-6-94	8-6-94
MAIN TO PROP. LINE	2"	P	5'		28' 2" CW	
PROP. LINE TO BLDG.	2"	P	19'		1990	

ENTERS: 1001

BRANCHED INTO:

TAP SIZE: 2"PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C.LOCATION 27' W OF LinwoodPRESSURE TEST: @ 100 psi For 1/4 Hrs. By M ParkerMAIN-SIZE 4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC X YEAR INSTALLED 1993DEPTH: 3 Ft. 0 In. LOCATION 3/8' North of East"A" P/S READING P TOTAL ANODES 1\* \_\_\_\_\_ 17\* \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P. Piser
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY