

LOCATION 1820 Linwood RdCITY GastoniaBETWEEN Mary LeeSTREET & Shannon

STREET


| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------|------|--------|----------------------|---------|---------|
| MAIN TO BLDG. | 3/4 | P | 3' new | Tied over 7-16-94 | | |
| MAIN TO PROP. LINE | | | | 90' exist | | |
| PROP. LINE TO BLDG. | | | | 3/4 P | | |

ENTERS: 1820

BRANCHED INTO:

TAP SIZE: 1/2PRESSURE 60 P.S.I. _____ INCHES W.C.LOCATION 14' N OFLinwood RdPRESSURE TEST: @ 100 psi For 1/4 Hrs. By M. ParkerMAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 93DEPTH: 3 Ft. 0 In. LOCATION 29' W OF Sharon"A" P/S READING 8 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



| Test Station | | |
|--|------|---------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | P-Riser |
| P/S Pipeline Lead - White Existing Main | E | |

ENG. DEPT. USE ONLY