

LOCATION 1930 Linwood Rd. CITY Gastonia  
BETWEEN Hoyle St. STREET & Mary Lee St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	3'	7-16-94	Tied over	100'
MAIN TO PROP. LINE					Existing	3/4 AW
PROP. LINE TO BLDG.						

ENTERS: 1930 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 133' N of Co of Linwood Rd.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL


MAIN SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In. LOCATION 13' E of Co of Mary Lee St.

"A" P/S READING Plastic TOTAL ANODES 1# 17# L.R. #

REMARKS: Bonded Dresser. Tied Trace wire OFF AT Tee.

Bare Main Replacement Program



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser .04
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY

→ Riser 10-13-94 1.6