

LOCATION 2300 Linwood Rd. CITY GASTONIA
 BETWEEN Anthony Dr. STREET & S. Myrtle School Rd. STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|-------------------|------------|----------------|------------|-------------|---------|---------|
| MAIN TO BLDG | <u>3/4</u> | <u>PLASTIC</u> | <u>60'</u> | <u>3-00</u> | | |
| MAIN TO PROP LINE | <u>3/4</u> | <u>PLASTIC</u> | <u>25'</u> | | | |
| PROP LINE TO BLDG | <u>3/4</u> | <u>PLASTIC</u> | <u>35'</u> | | | |

ENTERS 2314 Linwood Rd. BRANCHED INTO 2300 Linwood Rd.

TAP SIZE 3 way 3/4 PRESSURE 60 PSI INCHES W C LOCATION 178' W of S. Myrtle School Rd.
Plastic tee

PRESSURE TEST @ 100 PSI FOR 1/4 HRS. BY RL


MAIN SIZE 3/4 C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 10/21/91

DEPTH: 2 FT. 0 IN. LOCATION 75' N of Cap Linwood Rd.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # 00183289

REMARKS.

- Split Service -



| Test Station | | |
|---|----------|----------------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>S</u> | <u>Riser</u> |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | <u>PLASTIC</u> |