

LOCATION 2765 Linwood Rd. CITY BASTONIA
BETWEEN Castle Hill STREET & Lakewood Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>85'</u>	<u>4-2-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>20'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>65'</u>			

ENTERS: 2765 BRANCHED INTO: 0
TAP SIZE: 3/8 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 187' N of Lakewood Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

MAIN-SIZE 3" C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1978

DEPTH: 4 FT. 0 IN. LOCATION 17' E of Linwood Rd.

"A" P/S READING .70 TOTAL ANODES 1# _____ 17# 1 L.R. # 127419

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S	Rise plastic	
	P/S Pipeline Lead - White Existing Main	E		