

LOCATION 817 Little John St. CITY Gastonia
 BETWEEN Poplar St. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	82'	3-27-00		
MAIN TO PROP LINE	3/4	P	10'	BB.		
PROP LINE TO BLDG.	3/4	P	72'			

ENTERS Same BRANCHED INTO

TAP SIZE: 1/2 PRESSURE 60# PSI INCHES W C LOCATION 16' South of

Little John St. & 291' East of Poplar St.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY BB.

MAIN-SIZE 2 C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1991

DEPTH: 3 FT 6 IN LOCATION 16' South of Little John St.

"A" P/S READING Plastic TOTAL ANODES 1# 17# LR #

REMARKS New Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P. Riser
P/S Pipeline Lead - White Existing Main	E	