

LOCATION 3607 Little Mt. Rd CITY Gastonia
BETWEEN Woodbury Lane STREET & Old York Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>76'</u>		<u>9.26</u>	<u>.94</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>5'</u>		<u>75' of 1" BARE</u>	
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>71'</u>			

ENTERS: 3607 Little Mt. Rd. BRANCHED INTO:

TAP SIZE: 1/2" PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION E. Side of house


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By GK

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1994

DEPTH: 3 Ft. _____ In. LOCATION S. side of Little Mt. Rd.

"A" P/S READING .5 TOTAL ANODES 1* _____ 17* _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>.5</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY