

LOCATION 3800 Little Mt. Rd CITY Gastonia  
BETWEEN Woodbury Lane STREET & STREET

|                     | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------|------|--------|-----------|---------|---------|
| MAIN TO BLDG.       | 4"   | P    | 218'   |           | 9-30-94 |         |
| MAIN TO PROP. LINE  | "    | "    | 35'    |           |         |         |
| PROP. LINE TO BLDG. | "    | "    | 183'   |           |         |         |

ENTERS: 3800 Little Mt Rd BRANCHED INTO:  
TAP SIZE: PRESSURE 60 P.S.I. INCHES W.C. LOCATION W. Side of Homelite


PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By GL

MAIN-SIZE 4" C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1994

DEPTH: 3 Ft. In. LOCATION W. Side of Little Mt Rd.

"A" P/S READING .5 TOTAL ANODES 1# 17# L.R. #

REMARKS: READING on 4" C&W RISER is 1.6



| Test Station                               |      |       |
|--|------|-------|
| Reading & Location                         | Lead | Volts |
| P/S Pipeline Lead - Red<br>New Service     | S    | .5    |
| P/S Pipeline Lead - White<br>Existing Main | E    |       |

ENG. DEPT. USE ONLY