

LOCATION * 4809 Little mtw rd
4805 Little mtw rd CITY Gastonia

BETWEEN Gayle STREET & Benton STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	dw		12-12-00 - Bonded Services		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 4809 BRANCHED INTO: ←

TAP SIZE: 4805 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION

PRESSURE TEST: @ _____ psi For _____ Hrs. By _____


MAIN - SIZE 3/4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED _____

DEPTH: _____ Ft. _____ In. LOCATION

"A" P/S READING 1400 TOTAL ANODES 1* 1 17* 1 L.R. # _____

REMARKS: Bonded Services over to main -

*Note: 4809 Little mtw. Rd will be AN Isolated Service -



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	R'Sers	1.150
P/S Pipeline Lead - White Existing Main	R'SEer	1.400

ENG. DEPT. USE ONLY

- 4809 Little mtw Rd

- 4805 Little mtw Rd